

#15,148(a)

FILED FOR RECORD
at 12:05 o'clock P M



Farmers Electric Cooperative

A Touchstone Energy Cooperative

JUN 26 2018

JENNIFER LINDENZWEIG
County Clerk, Hunt County, TX
By *Jennifer Lindenzweig*

301 N. Hillcrest
Sulphur Springs, TX 75482

2000 I-30 E
Greenville, TX 75402

108 W. Marble
Wylie, TX 75098

Friday, June 8, 2018

Office of County Commissioners
PO BOX 1097
Greenville TX 75403

Farmers Electric Cooperative Member: BRADY POWELL
Service Order Number: 1805002801

Greetings:

Farmers Electric Cooperative, Inc. is requesting permission to construct electrical power distribution facilities across County Road 3213 which is located, 2406 ft west of CR 3212 in Hunt County, Texas.

Site location map and construction sketches are enclosed. The construction sketch details the proposed work. All road crossings will have a minimum vertical clearance of 22 feet.

If you have any questions, please contact me at any time.

Sincerely,

Tamara Williams
Project Coordinator

twilliams@farmerselectric.coop
Phone 903-513-2903

Submitted by Brandon Darrow
Field Engineering Coordinator

Enclosures


County Approval Section:

Approved: _____

Denied: _____

Authorized Signature: *J. Williams*

Date: 6-26-2018



Brady Powell
Service
Order#1805002801
Cross CR 3213 at
Pole#055804

HUNT

055801

118953

055803

CR-3213


055804

055805

168952

CR-3213

CR-3213



Location is 2406' West of CR 3212

shop



house



EASEMENT



#15,148(b)



Farmers Electric Cooperative

A Touchstone Energy® Cooperative

301 N. Hillcrest
Sulphur Springs, TX 75482

2000 I-30 E
Greenville, TX 75402

108 W. Marble
Wylie, TX 75098

June 5, 2018

Hunt County Commissioners Office
PO Box 1097
Greenville TX 75403

FILED FOR RECORD
at 12:05 o'clock P M
JUN 25 2018
JENNIFER LINDENZWEIG
County Clerk, Hunt County, TX
By: *Jennifer Lindenzweig*

Farmers Electric Cooperative Member: E. L TIPTON
Service Order Number: 1805006874

Dear Commissioners,

Farmers Electric Cooperative, Inc. is requesting permission to construct electrical power distribution facilities **across County Road 3320 which is located approximately 421 feet west from CR 3321 in Hunt County, Texas.**

Site location map and construction sketches are enclosed. The construction sketch details the proposed work. All road crossing will have a minimum vertical clearance of 22 feet.

If you have any questions, please contact your field engineering representative Griffin Trommer at 903-453-0556 office or 903-513-9152 mobile.

Please send approval back to our engineering group at: EngCC@farmerselectric.coop

Sincerely,

Griffin Trommer

Engineering Assistant
gtrommer@farmerselectric.coop

Enclosures

Submitted by:
Linda Graham
Field Engineering Coordinator
Office: 903-453-0716 Fax: 903-453-0660
lgraham@farmerselectric.coop

Approved Denied

Date: 6-26-2018

County Comments: _____

FARMERS ELECTRIC COOP
E L TIPTON
S/O 1805006874
POLE 028240

HUNT

CR 3320



CR 3321

