



15,305

Farmers Electric Cooperative

A Touchstone Energy® Cooperative

301 N. Hillcrest
Sulphur Springs, TX 75482

2000 I-30 E
Greenville, TX 75402

FILED FOR RECORD
at 11:00 o'clock 2 M
OCT 09 2018
JENNIFER LINDENZWEIG
County Clerk, Hunt County, TX
By: *J. Lindenzweig*
108 W. Marble
Wylie, TX 75098

Monday, October 1, 2018

Office of County Commissioners
PO BOX 1097
Greenville TX 75403

Farmers Electric Cooperative Member: Cruz Morales
Service Order Number: 1809003181

Greetings:

Farmers Electric Cooperative, Inc. is requesting permission to construct electrical power distribution facilities across County Road 3511 which is located, 1804 ft north of FM 2101 in Hunt County , Texas.

Site location map and construction sketches are enclosed. The construction sketch details the proposed work. All road crossings will have a minimum vertical clearance of 22 feet.

If you have any questions, please contact me at any time.

Sincerely,

Juan De La Cruz
Project Coordinator

jdelaacruz@farmersselectric.coop
Phone 903-513-0378

Submitted by Damaris Rivera
Field Engineering Coordinator

Enclosures

County Approval Section:

Approved: _____

Denied: _____

Authorized Signature: _____

Juan De La Cruz

Date: _____

FARMERS ELECTRIC COOP
CRUZ MORALES
S/O 1809003181
POLE 130426

CR 3511

HUNT

FM 2101



Locates: DIGTESS, CASH SUD P1-15FT FROM CR 3511

	<p>1</p> <p>Source: none Phase: B Span: 0 Comments: P130426</p> <p>Existing (1) 40-4 Existing (0) 4 ACSR Existing (1) VA1 Existing (1) VM2-11X Existing (1) VM2-12 Existing (1) VM5-9 PMB New (1) SC30 New (1) VA5-1E Retire (1) DVG19-25 Comment: L/O, MOVE TO NEW POLE (P4) Retire (1) J10</p>	<p>2</p> <p>Source: none Phase: B Span: 60 Comments: P130425</p> <p>Retire (60) 2 TPX SEC Retire (1) 40-4 Retire (1) J10 Retire (1) POLESET</p>	<p>3</p> <p>Source: 4 Phase: B Span: 81 Comments: 200A OHMP</p> <p>Existing (1) 2S 200A 120/240V OH Existing (81) 2 TPX SERV Comment: MOVE SERVICE TO NEW POLE (P4) Existing (1) K10</p>
<p>Misc. Remarks: RETIRE EXISTING SECONDARY 2TPX SPAN BETWEEN P130426 (P1) AND P130425 (P2). IF POSSIBLE RE-USE P2 POLE FOR NEW POLE AT P4 IF NOT BRING BACK TO FEC YARD. MOVE TRANSFORMER FROM P1 TO P4 AND MOVE EXISTING SERVICE TO P4. RUN PRIMARY FROM P130426 TO P5. HANG NEW TRANSFORMER ON P5 FOR NEW 200A OHMP SERVICE FOR DWMH. R.R-1 L. ATC DUE. REQUIRE EASEMENTS. REQUIRE HUNT COUNTY ROAD CROSSING PERMIT</p>	<p>4</p> <p>Source: 1 Phase: B Span: 75 Comments: NEW POLE</p> <p>New (150) 1/0 ACSR New (1) 40-4 New (1) DVG19-25 Comment: L/O New (1) E1-3 Comment: 28' GL New (1) E3-10 New (1) F1-3SH New (1) J10 New (1) VA5-4SS New (1) VM2-11 New (1) VM5-9 PMB</p>	<p>5</p> <p>Source: 4 Phase: B Span: 243 Comments: NEW POLE</p> <p>New (486) 1/0 ACSR New (19) 1/0 ACSR SAG New (1) 35-5 New (1) E1-3 Comment: 28' GL New (1) E3-10 New (1) F1-3SH New (1) VA5E New (1) VG19-15 New (1) VM2-11 New (1) VM5-9 PMB</p>	<p>6</p> <p>Source: 5 Phase: B Span: 60 Comments: 200A OHMP</p> <p>New (1) 2S 200A 120/240V OH New (10) 2 TPX SAG New (60) 2 TPX SERV New (1) K10</p>